

Microgrid Design and Operation

Project 1, due 4/9

Name Saif Elsaady

Project 1 objective: Build a microgrid to satisfy power needs for critical services in an island. The island is Oahu, Hawaii.

Problems for all students (80 points)

Task 1: Identify a critical facility (load) on Oahu. This is your choice. Recall some examples such as airports, hospitals, water treatment, military bases, police, fire, etc. Provide the name of the facility, latitude and longitude coordinates, use 4-6 sentences to describe the functions of the facility, and use 2-3 sentences to indicate how you believe the loads will change during the year, month, and day. **(10 pts)**

Name: University of Hawai'i at Mānoa

Latitude & Longitude Coordinates: 21.299824° N, 157.814823° W

Functions of the Facility: The University of Hawai'i at Mānoa is a premier institution for higher education and research in the Pacific, situated at 21.299824° N, 157.814823° W, in Honolulu. As the main campus of the University of Hawai'i system, it serves a diverse student body with a wide array of undergraduate, graduate, and professional programs. The university is a beacon of innovation and intellectual growth, with strong emphasis in areas like tropical agriculture, volcanic geology, oceanography, and Asian and Pacific studies, reflecting its unique geographical location. It not only provides educational services but also functions as a critical research hub, contributing to scientific advancement and economic development in Hawaii and beyond. Moreover, the campus supports the community through cultural enrichment and public service initiatives, making it an integral part of Oahu's societal fabric.

Load Changes: The energy load at the University of Hawai'i at Mānoa is likely to exhibit fluctuations throughout the year, with peaks during academic semesters when students and faculty are present and a reduction during breaks and the summer session. Monthly energy usage might be higher at the start and end of semesters due to the commencement and conclusion of academic activities. Daily load patterns are expected to peak during daytime hours when classes, administrative operations, and research activities are in full swing, with a noticeable dip during the night when these activities lessen.

Task 2: Create a DESIGN project in Xendee and build your base case analysis. **(30 pts)**


Utilize the below to create your project:

- Be sure to pick the correct latitude and longitude coordinates to begin.
- Include solar PV, battery energy storage, wind, and diesel generators in your analyses.
- For asset costs, use the average cost information from Lazard as you've done in previous models.
- For load, pick the load profile that is representative of the critical service you selected.

- For electricity costs, identify the appropriate [rate structure from Hawaiian Electric](#) and input those costs.
- For fuel, use the [West Coast On-Highway price](#) for diesel.

Provide the following:

- Screenshot of the GIS layout



- Screenshot of input information for each asset

Menu

Investment Specifications

Controller

Lifetime15Yrs

Investment Specifications

\$ Install Cost\$155,000

\$ Annual Support\$ / Year

\$ * Other\$

Save

Cancel

Delete

Wind Turbine

Technology Decision

ConsiderExistingExisting + MoreForcedForced + More

Existing NumberExisting AgeYearsMax Number

Investment Specifications

\$ Per Unit Install Cost\$300,000

\$ Lifetime20Years

\$ Variable Maintenance\$0.015 / kWh output

\$ Monthly Fixed Maintenance\$0 / Turbine/Month

Incentives

Investment Tax Credit30%

Amount Depreciable0%

MACRS YearsN/A

\$ Production Tax Credit\$0 / kWh

RECNo

Technical Specifications

Upload Wind Performance Data

Model100KW XANT M21

Rated Size100kW

Hub Height125ft

Power Factor100%

CurtailableYes

Electricity ExportNo

Compute

Save

Cancel

Delete

- Menu
- Decisions
- Financial
- Incentives
- System
- Catalog
 - Catalog
 - Save to Catalog
 - Manage
- SolarPV
 - Catalog Name
 - Custom

Solar PV

As Name *

Solar PV 2

Technology Decision

Consider

Existing

Existing + More

Forced

Forced + More

Existing Size

Existing Age

Max New Size

Investment Specifications

Inverter

Inverter Cost \$ 0 /kW

Lifetime 10 Years

Power Factor 100 %

Custom Inverter

Solar PV

Per Unit Install Cost \$ 1,750 /kW

Lifetime 20 Years

Variable Maintenance \$ 0 /kW output

Monthly Fixed Maintenance \$ 1.53 /kW/Month

Fixed Install Fees \$ 0

Define Space

Install Space 10,000,000 ft²

Unit Spacing

Panel Rating

Incentives

Investment Tax Credit 30 %

Amount Depreciable 85 %

MACRS Years 5

REC NO

Electricity Export YES

Production Tax Credit \$ 0 /kWh

Save

Cancel

- Decisions
- Investment Specs
- Technical Specs
- Incentives
- Charging & Exports
- Catalog
 - Catalog
 - Save to Catalog
 - Manage
- Storage
 - Name

Battery Energy Storage System

Technology Decision

Consider

Existing

Existing + More

Forced

Forced + More

Existing Size

Existing Age

Max New Size

Investment Specifications

Inverter

Inverter Cost \$ 65 /kW

Power Factor 100 %

Custom Inverter

Battery System

Per Unit Install Cost \$ 412 /kWh

Lifetime 15 Years

Variable Maintenance \$ 0 /kWh output

Monthly Fixed Maintenance \$ 0.4458 /kWh/Month

Fixed Install Fees \$ 0

Technical Specifications

Charging Efficiency 90 %

Charging Rate 0.25

Max SoC 100 %

Temperature Derating

- Temperature Derating Curve

Discharging Efficiency 90 %

Discharging Rate (4.0 Hours Duration) 0.25

Min SoC 5 %

Discrete Module Size

Max Annual Cycles

Min Annual Cycles 0

Emergency Min SoC 5 %

Reserve SoC 0 %

Incentives

Investment Tax Credit 30 %

Amount Depreciable 85 %

MACRS Years 5

Ancillary Services NO

Save

Cancel

- Screenshot of each tab for electricity

- Screenshot of each tab for electricity

Electric Utility Tariff

Tariff Name

Schedule J - General Service Demand

This tariff applies to any building load plus all technologies except for EV Chargers that are explicitly assigned to an alternative electric tariff.

Analysis
We'll not

Energy Charges

Demand Charges

Fees

Exports

Season Definition

Jan

Feb

Mar

Apr

May

Jun

Jul

Aug

Sep

Oct

Nov

Dec

Season 1

Season 1

Season 1

Season 1

Season 1

Season 1

Season 1

Season 1

Season 1

Season 1

Season 1

Season 1

Demand [\$ / kW]

Monthly

To add another season, click on any of the months to get a dropdown list and select the season that applies.

Contracted Tariff

Demand Charge Description

Add Coincident Hour

Add Tier

Add TOU Period

Season 1

Non-Coincident Rate

\$

13

/ kW

Show Demand Constraints

Electric Utility Tariff

Tariff Name

Schedule J - General Service Demand

This tariff applies to any building load plus all technologies except for EV Chargers that are explicitly assigned to an alternative electric tariff.

Energy Charges

Demand Charges

Fees

Exports

Fees

Access Fee

\$

98.2

/ Month

Contract Demand Fee

\$

0

/ kW

Standby Charge

\$

0

/ kW/Month

Electric Utility Tariff

Tariff Name

Schedule J - General Service Demand

This tariff applies to any building load plus all technologies except for EV Chargers that are explicitly assigned to an alternative electric tariff.

Analysis Options

Energy Charges

Demand Charges

Fees

Exports

Exports

Sales Price

Sales Price Same As Tariff

Net Metering Constraint

YES

Net Metering Limit

100 %

Contracted Sales Price

Rates For electricity are equal to the rates set for Energy Charges and apply at the same TOU periods defined for Energy Rates. For tiered Energy Rates, the Tier 1 rates are used to set the sales price.

Show Export Constraints

- Screenshot of the load profile

Miami is closest thing to Hawaii

End-use	Origin	Annual Usage	Peak Demand
⚡ Electricity-Only	Imported NREL catalog: Miami, FL; LargeOffice; Pre 1980.	1.000 GWh	221.0 kW

Electricity Only Load Shape

Week

Weekend

Peak

Electricity Only Load Shape - Week

Click month name to show/hide series...

Remove Electricity-Only

January

February

March

April

May

June

July

August

September

October

November

December

- Screenshot of diesel fuel price entry

Diesel Fuel Purchases

Monthly Access Fee

\$

0

Fee

Monthly

4.6660 /Gallon

Emissions Factor

0.24964 kgCO₂/kWh


Annual Limit

Gallons


Task 3: Run an optimization termed “Base case”. (10 pts)

Provide the following:

- Screenshot of the techno-economic results



- Screenshot of dispatch for January weekday and for July weekday



- Short paragraph with 3-5 sentences discussing why assets were selected by Xendee (or not selected) and include description of the dispatch profile to defend your statements (e.g., battery used for peak shaving).


The selection of assets by Xendee for the University of Hawai'i at Mānoa's microgrid project includes solar PV, wind turbines, and a battery energy storage system, reflecting an integrated approach to harness renewable energy sources and enhance grid resilience. The deployment of solar PV is strategically aligned with Hawaii's ample sunlight, contributing significantly to the daytime energy supply and minimizing reliance on grid electricity, as indicated by the dispatch profiles which show solar PV meeting a substantial portion of the load during daylight. Wind turbines have been

included to provide additional power generation, particularly useful during periods when solar energy may be insufficient, thereby ensuring a more constant energy flow throughout the day. The battery energy storage system plays a critical role in peak shaving, evidenced by its utilization pattern of charging during peak solar generation and discharging during times of high demand or reduced renewable generation. This setup not only curtails demand charges but also bolsters the microgrid's capability to provide consistent energy amidst the variability of renewable sources.



Task 4: Update the asset cost inputs to include the low-end of the ranges provided by Lazard. Run a least-cost optimization termed “Low asset cost”. **(10 pts)**

Provide the following:

- Screenshot of the techno-economic results



- Screenshot of dispatch for January weekday and for July weekday




- Short paragraph with 3-5 sentences discussing why assets were selected by Xendee (or not selected) and include description of the dispatch profile to defend your statements (e.g., battery used for peak shaving).

After updating the asset cost inputs to reflect the lower end of Lazard's cost range and running a "Low asset cost" optimization, Xendee selected a diverse mix of solar PV, battery storage, and wind turbines for the University of Hawai'i at Mānoa's microgrid. The larger capacity of solar PV, amounting to 3.85 MW, highlights an effort to maximize the use of Hawaii's abundant solar resources for cost-effective, renewable power generation. The battery storage system, at 2.09 MWh, is likely chosen not only for its potential in peak shaving—where stored energy is used during times of high electricity prices or demand—but also for enhancing the reliability of power supply when solar or wind generation is intermittent. A smaller inclusion of wind turbines at 1 MW indicates a supplementary role to the solar generation, likely catering to periods when solar resources are minimal. The dispatch profiles exhibit a significant reliance on solar PV during daylight hours, with batteries supplying power during peak periods and reducing utility purchases, thereby optimizing costs and enhancing the project's sustainability.



Task 5: Return asset costs to their nominal values from Task 3. Now run a Resiliency analysis for a 3-day outage (20 pts)

Provide the following:


- Screenshot of the techno-economic results



- Screenshot of dispatch for January weekday and for July weekday



- Screenshot of dispatch for the Emergency period when the outage occurs



- Short paragraph with 4-7 sentences discussing why assets were selected by Xendee (or not selected) and include description of the dispatch profile to defend your statements (e.g., generator needed to guarantee power). *Be sure to mention if and why the assets and sizes from Task 5 are different from Task 3.*

The Xendee optimization for the University of Hawai'i at Mānoa's microgrid project has strategically selected assets that align with the university's energy needs and operational objectives. The inclusion of a considerable solar PV capacity and a complementary battery energy storage system underlines a commitment to clean energy and sustainability, harnessing Hawaii's abundant solar resources. The solar PV directly offsets daytime energy needs, with excess power used to charge the battery storage, which then provides energy during peak demand periods or when solar production is insufficient, effectively shaving peak loads. The presence of wind turbines and diesel generators within the asset mix demonstrates a layered approach to resilience, with the turbines contributing to the renewable energy portfolio and the diesel generators serving as a reliable backstop to guarantee power during periods when renewable sources are not available or during system contingencies. The dispatch profile indicates that solar and wind are the primary energy sources, with storage acting as a buffer and diesel generators as a last resort, ensuring continuous power supply and operational resilience for the critical facility. This carefully designed energy system aims to provide an economically feasible and environmentally sound solution for the university's energy demands.

The selection and sizing of assets in Task 5 as compared to Task 3 could be due to various factors, including the optimization goals set within Xendee, such as cost minimization or CO2 emission reduction, and the operational constraints or resiliency requirements of the University of Hawai'i at Mānoa. Variations in asset sizes may result from updated cost inputs or a refined understanding of the load profiles and patterns, leading to more precise sizing to avoid over- or under-provisioning. Additionally, any changes could reflect new or more accurate data on the expected performance of the technologies, such as improvements in solar PV efficiency or battery storage capacity. If there is a shift toward greater resiliency, it might explain an increased reliance on storage or backup generators to ensure stability during outages or fluctuations in renewable generation. Each iteration of the design

aims to strike a balance between technical feasibility, economic viability, and the institution's sustainability targets, which could account for shifts in the energy strategy from one task to another.